



NOTES:

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
3. ROOF PENETRATIONS EXCEEDING 120°F, REFER TO THE IB HOT PIPE FLASHING DETAIL.
4. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAINMENTS, OR COVER WITH ALUMINUM FOIL TAPE

Scale: NTS	Detail Name: IB Pipe Flashing	Detail Number: PS - 02
Submitted By: Address: Telephone:		Project: Address: