



NOTES:

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
3. THIS DETAIL TO BE USED FOR ROOF PENETRATIONS EXCEEDING 120°F (HEATED STOVE PIPES, DRYER EXHAUSTS, FLUMES, ETC.)
4. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAMINANTS.

Scale: NTS	Detail Name: IB Hot Pipe Flashing	Detail Number: PS - 05
Submitted By: Address: Telephone:		Project: Address: