



**NOTES:**

1. MINIMUM OF 4 IB FASTENERS PER PIPE FLANGE.
2. FOR BATHROOM / MECHANICAL VENT APPLICATION: INSTALL BOTH INSECT SCREENS PRIOR TO INSTALLING VENT.
3. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.

Scale:  
NTS

Detail Name:

**IB Dryer - Exhaust Vent**

Detail Number:  
**PS - 07**

Submitted By:  
Address:  
Telephone:

Project:  
Address: