



**NOTES:**

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. EXTEND REINFORCING FABRIC A MINIMUM OF 4" VERTICALLY AND FINGERS A MINIMUM OF 2" BEYOND PENETRATION

Scale:  
NTS

Detail Name:

***Liquid Flashing At Pipe Penetration***

Detail Number:

***PS - 12***

Submitted By:  
Address:  
Telephone:

Project:  
Address: