



NOTES:

1. ROOF SLOPE, DRAIN SIZE AND NUMBER OF DRAINS SHALL BE IN ACCORDANCE WITH THE LOCAL CODES.
 2. THE HOLE IN THE MEMBRANE SHALL EXCEED THE DIAMETER OF THE DRAIN PIPE, BUT SHALL BE NO LESS THAN 1/2" FROM THE ATTACHMENT POINTS OF THE DRAIN CLAMPING RING.
 3. ALL BOLTS OR CLAMPS MUST BE IN PLACE TO PROVIDE CONSTANT COMPRESSION ON IB WATER STOP SEALANT.
 4. MEMBRANE DRAIN LINERS ARE NOT ELIGIBLE FOR AN IB TOTAL SYSTEMS WARRANTY.
 5. RE-ROOF APPLICATIONS: REMOVE EXISTING LEAD, FLASHING MATERIAL & ENSURE THE DRAIN RING IS COMPLETELY CLEAN DOWN TO BARE METAL.
 6. OVERFLOW DRAINS ARE THE SAME, EXCEPT FOR THE RESTRICTOR COLLAR.
 7. TARGET SHEETS CAN BE INSTALLED BEFORE OR AFTER FIELD MEMBRANE.
- REFER TO RD-03 FOR TAPERED SUMP LAYOUT PARAMETERS

Scale:

NTS

Detail Name:

Tapered Sump Clamping Ring Drain

Detail Number:

RD - 02

Submitted By:

Address:

Telephone:

Project:

Address: