



NOTES:

1. SUMP AREAS AT DRAINS SHOULD BE FORMED INTO THE DECK OR INSTALLED WITH TAPERED INSULATION.
2. APPROVED DRAIN TYPES INCLUDE: CAST IRON, SPUN ALUMINUM, OR COPPER WITH CLAMPING RINGS.
3. MEMBRANE DRAIN LINERS ARE NOT ELIGIBLE FOR IB TOTAL ROOF SYSTEM WARRANTIES AND REQUIRE PRE-APPROVAL FOR USE ON IB WARRANTED PROJECTS.
4. RE-ROOF APPLICATIONS: AN APPROVED SEPARATION LAYER IS REQUIRED TO FULLY DIVORCE THE IB MEMBRANE FROM ANY EXISTING INCOMPATIBLE MATERIALS.
5. TARGET SHEETS CAN BE INSTALLED BEFORE OR AFTER FIELD MEMBRANE.

Scale: NTS	Detail Name: Drain - Overflow Membrane Layout	Detail Number: RD - 03
Submitted By: Address: Telephone:		Project: Address: