



NOTES:

1. SINGLE COURSE WALL FLASHING MAXIMUM HEIGHTS:
 - A. 18" FOR INDUCTION WELDED FLASHINGS.
 - B. FOR WALLS EXCEEDING MAXIMUM HEIGHTS, REFER TO INDUCTION WELDED TALL WALL DETAIL.
2. SECURE FLASHINGS AND METAL WORK IN ACCORDANCE WITH IB SPECIFICATIONS AND FLASHING SECUREMENT TABLE.
3. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
4. REFER TO FT AND/OR PT DETAILS FOR APPROVED FLASHING AND WALL TERMINATIONS

APPROVED SUBSTRATE / SEPARATION:

NEW CONSTRUCTION - INDUCTION WELDED

- 1/2" PLYWOOD, 7/16" OSB, 1/2" APPROVED GYPSUM COVER BOARD, POURED / PRECAST CONCRETE, OR CEMENT BLOCK / MASONRY WALLS.

INDUCTION WELDED RECOVER OVER APPROVED EXISTING WALL AND BASE FLASHINGS

- FULL SEPARATION REQUIRED WITH MINIMUM 1/4" APPROVED GYPSUM COVER BOARD

Scale: NTS	Detail Name: Induction Welded Wall	Detail Number: WD - 07
Submitted By: Address: Telephone:		Project: Address: