



NOTES:

1. SEALANTS AND CAULKING REQUIRE PERIODIC OWNER MAINTENANCE.
2. ROOF PENETRATIONS EXCEEDING 120°F, REFER TO THE HOT PIPE FLASHING DETAIL.
3. CLEAN PENETRATION PRIOR TO FLASHING TO REMOVE ALL BITUMINOUS RESIDUE OR CONTAINMENTS, OR COVER WITH ALUMINUM FOIL TAPE.

Scale: NTS	Detail Name: IB Alternate Pipe Flashing	Detail Number: PS-04
Submitted By: Address: Telephone:		Project: Address: