



NOTES:

1. IB FASTENERS & MEMBRANE PLATES INSTALLED 6" O.C. WITH A MINIMUM OF 3 FASTENERS FOR PIPES LESS THAN 12" IN DIAMETER (12" O.C. WITH MINIMUM OF 4 FASTENERS FOR PIPES GREATER THAN 12" DIAMETER).
2. EXTEND REINFORCING FABRIC A MINIMUM OF 4" VERTICALLY AND FINGERS A MINIMUM OF 2" BEYOND PENETRATION

Scale: NTS	Detail Name: <i>Liquid Flashing At Pipe Penetration</i>	Detail Number: <i>PS - 12</i>
Submitted By: Address: Telephone:		Project: Address: