



**NOTES:**

1. IB EDGE METAL TO BE FASTENED WITH CORRESPONDING STAINLESS STEEL OR COPPER NAILS AT 4" O.C. STAGGERED
2. SECURE FLASHINGS AND METAL WORK IN ACCORDANCE WITH IB SPECIFICATIONS AND FLASHING SECUREMENT TABLE.
3. COPPER EDGE METAL REQUIRES USE OF STAINLESS STEEL CLEAT AND FASTENERS.
4. CLEAN AND WIPE METAL EDGING PRIOR TO INSTALLATION.
5. METAL NOT ELIGIBLE FOR COVERAGE IN IB TOTAL SYSTEMS WARRANTY. SEALANTS & COVERSTRIP REQUIRES PERIODIC OWNER MAINTENANCE.

Scale: NTS	Detail Name: <b><i>Drip Edge for Non-Clad Metal - Cleated</i></b>	Detail Number: <b><i>PE - 15</i></b>
Submitted By: Address: Telephone:		Project: Address: